

**MINISTRY OF OIL
MIDLAND REFINERIES CO. (G.CO.)
(DAURA REFINERY)**

ADVERTISEMENT

**MIDLAND REFINERIES CO. ANNOUNCES FOR PURCHASING THE MATERIALS AS STATED
BELOW:-**

REQ.NO.	DESCRIPTION	QTY.	PRICE/ ID DINAR	BID BOND/\$
3613/2008	FIRE SIREN SYSTEM	4 NOS	50000	900

NOTE:

- 1. THE REQ. TO BE SOLD IN IRAQI DINAR, UN RETURNABLE.**
2. PRICES (OFFERS) TO BE SUBMITTED IN US DOLLAR CIP BAGHDAD (DAURA REFINERY).
3. CLOSED (TECHNICAL & COMMERCIAL OFFERS TO BE SUBMITTED SEPARATELY).
4. THE OFFERS MUST BE SUBMITTED BY (DHL) & ALL THE OFFERS THAT SEND BY E-MAIL WILL BE REFUSED.
5. ALL DOCUMENTS (PROFILE) MUST BE SUBMITTED BEFORE PURCHASING THE REQ. OR ENCLOSE WITH THE TECHNICAL OFFER OTHERWISE THE OFFER WILL BE REFUSED.
6. TERMS OF PAYMENT IS L/C TO BE PAID 100% AFTER THE RECEIPT OF GOODS IN BAGHDAD COMPLETE AND AS ORDER.
7. AN UNCONDITIONAL PERFORMANCE BOND OF 5% OF TOTAL AMOUNT OF THE L/C TO BE SUBMITTED BEFORE OPENING OF THE L/C IN FAVOUR OF (MIDLAND REFINERIES CO.) TO BE RELEASED AFTER THE RECEIPT OF GOODS COMPLETE AND AS ORDERED.
8. 1% OF TOTAL VALUE DELAY PENALTY SHOULD BE APPLIED FOR EACH WEEK DELAY.
9. 3% FROM TOTAL VALUE OF THE PURCHASE ORDER FOR IRAQI COMPANIES ALSO INCREASE THE PAYMENT OF PAYABLE IN IRAQI DINAR TO BE DEDUCTED AS TAXES & NOT RELEASE UNLESS WE GET APPROVAL ISSUED FROM OUR TAXES OFFICE.
10. 0.002 FROM TOTAL VALUE OF L/C TO BE DEDUCTED AS STAMP CHARGE.
- 11. THE BID BOND SHOULD BE SUBMITTED AS MENTIONED ABOVE ENCLOSE WITH A TECHNICAL OFFER AS LETTER OF GUARANTEE OR CERTIFIED CHECK OR BANK GUARANTEE ISSUED FROM ANY IRAQI BANK RELEASED IMMEDIATELY IN CASE THE REQUEST IS NOT AWARDED TO THE COMPANY.**
- 12. CLOSING DATE IS-29/7/2008 TILL (12:00) O, CLOCK (NOON).**

**D.Y. AL-KASHAB
G.MANAGER**

QTY: 4

REQ NO :- 3613 / 2008

Siren System

- The siren system to be for multipurpose use, it can be used by fire brigades as well as by civil defence organizations.
- Audibility from 3 to 5 km includes.
 - 1- Fire alarm.
 - 2- Air- raid alarm.
 - 3- End of air raid.
 - 4- Siren checking.
- Warning programmers for control box to be:
 - 1- Fire alarm (signal 3X (10-15) seconds with 2 intervals each of (5-7 sec).
 - 2- Siren checking (signal of 10-15 sec).
 - 3- Air- raid alarm (signal of 1 min frequency going up and down).
 - 4- End of air-raid (signal of 1 min no frequency change).
- The power supply is 220 V /50 HZ single phase.
- Weight is 5 Kg or less.
- The system consist of :
Control box, siren checking control box, siren main switch and manual, central control switch, remote-control alarm switches, push button, cables electric items.
- Electric motor with 3kw, sound frequency more 400 Hz.
- Made of light alloy to be corrosion-proof, water-proof.
- Pole mounted about 2m with base plate.